



Attestation of Conformity

No. N8A 098081 0013 Rev. 02

Holder of Certificate: Jolywood (Taizhou) Solar

Technology Co., Ltd.

Kaiyang Rd. Jiangyan Economic Development Zone

225500 Taizhou City, Jiangsu Province PEOPLE'S REPUBLIC OF CHINA

Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704061930402-07

Date, 2021-03-30

(Zhulin Zhang)



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.





Attestation of Conformity

No. N8A 098081 0013 Rev. 02

Model(s): 1)JW-D72N-xxx, xxx= 365-410, in step of 5

2)JW-D60N-xxx, xxx= 305-340, in step of 5 3)JW-HD144N-xxx,xxx=390-420, in steps of 5 4)JW-HD120N-xxx, xxx=325-350, in steps of 5 5)JW-HD144P-xxx, xxx=390-415, in steps of 5

6)JW-HD120P-xxx, xxx=325-345, in steps of 5 7)JW-HD156N-xxx, xxx=425-455, in steps of 5

8)JW-HD156P-xxx, xxx=425-445, in steps of 5 9)JW-HD144N-xxx, xxx=430-470, in steps of 5

10)JW-HD120N-xxx, xxx=360-379, in steps of 5

11)JW-HD144P-xxx, xxx=430-450, in steps of 5 12)JW-HD120P-xxx, xxx=360-375, in steps of 5

13)JW-HD144N-xxx, xxx=525-555, in steps of 5

14)JW-HD120N-xxx, xxx=435-460, in steps of 5 15)JW-HD144P-xxx, xxx=525-545, in steps of 5

16)JW-HD120P-xxx, xxx=435-450, in steps of 5 17)JW-HD132N-xxx, xxx=485-505, in steps of 5

18)JW-HD108N-xxx, xxx=395-415, in steps of 5 xxx is standing for rated output power at STC.

Parameters: Construction: Framed or frameless, with Junction box,

Test Laboratory:

Cable and Connectors.

Safety Class: Class II

Maximum System Voltage: 1500 V DC

Fire Safety Class: Class C according to UL 790

Yangzhou Opto-Electrical Products

Testing Institute,

No. 10 West Kaifa Road, Yangzhou,

225009 Jiangsu, P. R. China.

Tested EN IEC 61730-1:2018

EN IEC 61730-1:2018/AC:2018-06

according to: EN IEC 61730-2:2018

EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

